

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1041251

Product: Circuit-breaker

Type: BD 250, BD 250N, BD 250S

Rating: In = 100, 160, 250 A, Un = 690 V

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad

Trade mark:

The test results are stated in the test-report No.: 403261-01/01 of: 08.09.2004

Application No.: 403261-01

A sample of the product was found to be in conformity with:
ČSN EN 61000-4-5:97+Z1:01, ČSN EN 61000-4-2:97+A1:99+Z1:01, ČSN EN 61000-4-3:03 ed. 2+A1:03,
ČSN EN 60947-1:00 ed. 2+A1:01+A2:02, ČSN EN 60947-2:04

The validity of the certificate is limited to: 30.11.2007

14.10.2004

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp