

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1041216

Product: Circuit-breakers with electronic trip

Type: BH630 + electronic trip SE- BH-XXXX MTV8, SE- BH-XXXX DTV3

Rating: In = 250, 400, 630 A; Un = 690 V

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad

Trade mark:

The test results are stated in the test-report No.: 403262-01/01 of: 07.09.2004

Application No.: 403262-01

A sample of the product was found to be in conformity with:
ČSN EN 60947-1:00 ed.2+A1:01+A2:02, ČSN EN 60947-2:04

The validity of the certificate is limited to: 30.11.2007

1.10.2004

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp