

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 71 - Troja

## CERTIFICATE

No.: 1031235

**Product:** Circuit breakers

**Type:** BL 1600

**Rating:** Ue = 690 V AC, Iu = 1600 A, Icu = 65 kA

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad

**Trade mark:**

**The test results are stated in the test-report No.:** 302416-01/01 of: 07.07.2003

**Application No.:** 302416-01

**A sample of the product was found to be in conformity with:**  
ČSN EN 60947-1:00, ČSN EN 60947-2:98+A1:99  
ČSN EN 55022:99+A1:01, ČSN EN 60947-4-2:01ed.2+A1:02

**The validity of the certificate is limited to:** 30.9.2006

11.7.2003

Prague

  
Pavel Kudrna  
Certification and Inspection Manager



Stamp